

REQUEST FOR PROPOSALS

ADDENDUM # 1 Questions and Clarifications

Underground Storage Tank (UST) Leak Detection System RFP #FED2019-09

TO: Prospective Proposers
FROM: Martha Howarter, Director of Federal Programs
DATE: May 21, 2019
SUBJECT: Addendum No. 1 – Questions and Clarifications

The following is included as part of Addendum No.1 and supersedes the language/requirements set forth in the original "Request For Proposals".

ADDENDUM # 1 – Questions and Clarifications

| # | Questions submitted or asked | Response from GPMTD |
|----------|---|---|
| 1 | Modification/Clarification: Scope of Work 2-3 Minimum System Requirements | <i>Pressurized Line Leak Detection (PLLD) System should be included under Section 2-3, Minimum System Requirements.</i> |
| 2 | Modification/Clarification: Scope of Work 2-3 Minimum System Requirements “Additional vendor recommendations should be included as options with related costs.” | <i>Any Vendor recommendations that are not listed in the “Minimum System Requirements” should be included in the proposal packet as “Options” with related costs.</i> |